



AC 038





Główny Instytut Górnictwa Jednostka Certyfikująca Zespół Certyfikacji Wyrobów KD "Barbara" ul. Podleska 72 43-190 Mikołów, tel. (+48) 32 3246550 fax. (+48) 32 3224931 www.gig.katowice.pl

This certificate and its schedules may only be reproduced in its entirety and without change

Products Certification Program PCW-ISO/IEC-1b Code ICS 13.240

[1] EC-TYPE EXAMINATION CERTIFICATE



- [2] Equipment, protective systems and components intended for use in potentially explosive atmospheres Directive 94/9/EC
- [3] EC type examination certificate:

KDB 13ATEX0041X

[4] Equipment:

Junction box type KZPM *-*/*(P)

[5] Manufacturer:

JSC "VELAN"

[6] Address:

Velanovskaya street 1, Zelenokumsk Stavropol Region, 357911 Russia

- [7] This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- Główny Instytut Górnictwa, Notified Body number 1453 in accordance with Article 9 of [8] Directive 94/9/EC of 23 March 1994, certifies that this equipment and protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive. recorded in The examination and test results are confidential report KDB No. 13.048 [T-7003]
- [9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2009; EN 60079-7:2007

- [10] If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- [11] This EC-type examination certificate relates only to the design and construction of the specified equipment and protective system in accordance with Directive 94/9/EC. Further requirements of the Directive may apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.
- [12] The marking of the equipment shall include the following:



Specjalista ds. Certyfikacji Irządzeńy zeciwwybachowych dr inż. Michał Górny



Zespołu Cartyfikacji Wyrobów KD "BAFBARA" Mikołów dr hab. inż. Krzysztof Cybulski proj. Gi6

Date of issue: 10.04.2013

Date of English version: 10.04.2013

Page 1 of 3



Główny Instytut Górnictwa Jednostka Certyfikująca Zespół Certyfikacji Wyrobów KD "Barbara"



13

SCHEDULE

14

EC-Type Examination Certificate KDB 13ATEX0041X

[15] **Description:**

The junction box KZPM... is equipped with enclosure made of light alloy AlSi12. The enclosure consists of the body and the cover fixed to the body with M6 or M8 screws. Terminals of type WK... WKM... or WKN... made by Wieland (marking II2GD IM2 Ex e I/II, certificate KEMA 02ATEX2114U) or WDU... made by Weidmüller (marking II2GD Ex II, certificate KEMA 98ATEX1683U) are placed inside the box. The nominal current and nominal voltage of the box depend on applied terminals. In body of the box there are openings with thread M20x1,5; M25x1,5; M32x1,5; M40x1,5; M50x1,5 or M63x1,5 for montage of cable inlets. Unused openings are blanking by threaded plugs.

In the name of the box type, particular symbols mean:

KZPM *-*/* P

Spring terminals

(for screw terminals does not exist)

Number of terminals

Nominal current of the box

40EO

1.2, 2.1, 2.2, 2.3, 2.4, 3.1, 3.2, 3.3, 3.4, 4.1,4.2, 4.3, 4.4 or 5 depend on size of the box and number of openings for cable inlets

Technical parameters:

Max. Nominal voltage	900 V 690	
Max. Number of terminals	74	
Max. Nominal current	A 124	
Dust and water protection	IP 6	6
Ambient temperature	-20°C ÷	+50°C

Nominal voltage and nominal current are as follow, depend on the type of used terminals:

	Maximum number of Wieland terminals								
	WK	WKM	WK	WKM	WK	WK	WKN	WKN	WKN
Type	2.5/U	2,5/U	4/U	4/U	6/U	10/U	16/U	35/U	70/U
of the box									0.0000
	690V	690V	690V	690V	690V	690V	690V	690V	690V
	16A	12A	18A	28A	32A	38A	55A	85A	124A
KZPM1.X	-	4	-	4	-	-	-	-	-
KZPM2.X	_	8	-	8	-	-	-	-	-
KZPM3.1	-	12	-	12	-	-	-	-	-
KZPM3.2 ,3.3 ,3.4	12	12	18	26	14	10	8	6	_
KZPM4.1	-	35	-	30	-	-	-	-	-
KZPM4.2, 4.3	34	35	36	30	28	20	18	12	6
KZPM4.4	34	35	36	30	28	201	3 or pietwa	12	8
KZPM5	34	50	74	30	56	30	30	430	8

This certificate and its schedules may only be reproduced in its entirety and without change.

Page 2 of 3



Główny Instytut Górnictwa Jednostka Certyfikująca Zespół Certyfikacji Wyrobów KD "Barbara"



SCHEDULE

EC-Type Examination Certificate KDB 13ATEX0041X

	Maximum number of Weidmüeller terminals						
Type	WDU 2,5/U	WDU 2,5N	WDU 4	WDU 4N	WDU 6		
of the box	- 0						
	550V	440V	690V	440V	550V		
	20A	16A	35A	28A	38A		
KZPM1.X	_	4	-	4	_		
KZPM2.X	-	8	_	8	_		
KZPM3.1	-	12	_	12	_		
KZPM3.2 ,3.3 ,3.4	12	12	18	26	-		
KZPM4.1	-	35	-	30	_		
KZPM4.2, 4.3	34	35	36	30	28		
KZPM4.4	34 -	N 350 F	36	30	28		
KZPM5	60	60	5/74	74	56		

[16] Test report:

Sprawozdanie KDB Nr 13.048

[17] Special condition for save use:

- The junction box should be equipped with cable inlets certified as Ex e or Ex d components.
- The box can be used for connecting intrinsically safe circuits, provided, that the insulating distances between intrinsically safe and non-intrinsically terminals are in accordance with the requirements of EN 60079-11.

[18] Essentials health and safety requirements:

Met by compliance with standards:

EN 60079-0:2009; (PN-EN 60079-0:2009);

EN 60079-7:2007; (PN-EN 60079-7:2010);

